



FSB150

Model									
FSB150	L/Min Non Restricted		L/Min Restricted		kW HP	Volts/Hz	dB(A)	KG	CM-hxwx d
	0 Bar 175	2 Bar 153	0 Bar 119	2 Bar 113	1.1 1.50	380-415/50 220-240/50	74	27	30x56x33



VTS75D

Model								
VTS75	L/Min	Ltrs	Bar	kW HP	Volts/Hz	dB(A)	KG	CM-hxWxd
	120	23	8	0.55 0.75	220-240/50	54	64	65x93x48
VTS75D	L/Min	Ltrs	Bar	kW HP	Volts/Hz	dB(A)	KG	CM-hxWxd
	120	23	8	0.55 0.75	220-240/50	54	71	65x93x48
FAD	1 Bar	2 Bar	3 Bar	4 Bar	5 Bar	6 Bar	7 Bar	8 Bar
L/Min	108	96	85	74	65	57	48	45

-40°C Dewpoint based on 50% duty cycle

28/01/25



bafsa

Atkinsons Way, Foxhills Industrial Estate, Scunthorpe, North Lincolnshire, DN15 8QJ
Fire Protection Centre Limited. Registered in England No. 03798539 VAT No. 279 1182 80
Telephone – 01724 854199 Email – sales@fireprotectioncentre.com
Website – www.fpcdatacentre.co.uk